



**WE SERVE TO SAVE  
REGIONAL FIRE OFFICE**

**GUJARAT STATE FIRE PREVENTION SERVICES, VADODARA**

"VUDA BHAVAN", 4<sup>th</sup> Floor, Near L&T Circle, V.I.P. Road, Karelibaug, Vadodara-390018.

E-mail: rfovadodarasfps@yahoo.com/rfo-sfps-vadodara@gujarat.gov.in. (☎)0265-2466101.



No. RFO-SFPS/F.No- 18/NOC-School Building-66/204/2024.

Date:-29/06/2024.

**FORM B13**

(See sub-rule (1) of rule 23)

**Fire Safety Certificate**

Certified that the **M/S. NDDB Campus-Anandalaya School Building**, At.- Anand, Ta.-Anand, Dist.-Anand, Gujarat comprised of Ground + 2 Floors having School activity in owned/occupied by **M/S. NDDB Campus-Anandalaya School Building** have complied with the fire prevention and fire safety requirements in accordance with section-18 and verified by the Station Fire Officer – Anand Nagarpalika on Dated.-25/06/2024 in the Presence of **Mr. RupeshKumar A Darji, Senior Manager** and that the building/premises is fit for occupancy with effect from for a period of (from date:-29/06/2024 to date:-28/06/2027) Three (03) years in accordance with rules and subject to compliance of any specific laid by the issuing officer.

- Note:** - 1. This Fire Safety Certificate should be cancelled out immediate if found not obeying of any instruction and Applicable CGDCR, Act, Rules and Regulation for Fire Safety Certificate.  
2. This Fire Safety Certificate Issued as per the Director, GSFPS, Gandhinagar Circular Letter NO:-SFS/FN-85.1/55/2022, Dated- 12/01/2022.  
3. This Fire Safety Certificate Issued Subject to up keep of Fire Extinguisher as per IS-15683 & maintain as per IS-2190.  
4. This Fire Safety Certificate Issued Subject to maintain entire Fire Protection System on Quarterly basis as per Annual Maintenance Contract & keep in healthy Conditions.  
5. Fire Safety Certificate is Issued for Fire Safety Certificate Purpose Only.

**Issued Date:-29/06/2024.**



*[Signature]* 29/06/2024

**Regional Fire Officer  
State Fire Prevention Services  
Vadodara Region.**

**ENDORSEMENT**

The Certificate issued by Fire service stand cancelled and annulled due to \_\_\_\_\_ . (Reasons to be recorded.)